



Office of the Executive Engineer

Public Works Department

OFFICE OF THE EXECUTIVE ENGINEER	
PUBLIC WORKS DIVISION, AURANGABAD.-431001 PH No 0240-2331174	
No DM/ 1029/2021	Date 11/10/2021

BUILDING SAFETY CERTIFICATE



This to certify that the construction of school building for VNSP Mandal's R.Scholarden School at N-9 CIDCO Aurangabad. Tq.Dist Aurangabad. Has been completed as per plan sanctioned AMC Aurangabad. by the trust itself under technical supervision of Arch. Arun N. Bore, N-2 Cidco Aurangabad B.Arch M.Tech Reg No CA/9722123. with reference to vide principal V.R. Sholardan school, letter No VRSS/2021-22/418 Date 16/9/2021

Built up Area of Building

Built up Area Lower Ground Floor	572.51 Sqmt.
Built up Area upper ground floor	572.51 Sqmt
Built up Area First Floor	572.51 Sqmt

This Building has been inspected by me The Assitstant Engineer Grade I Construction Sub Division No.1 Aurangabad. The berief Specifications of the building as following

1. R.C.C. Framed Structure.
2. Superstructure in B.B. Masonry
3. T.W.Door and M.S. Windows
4. Kota Stone Flooring
5. Ramp for Handicapped persons
6. Fire extinguisher installed at each floor

The building seems to be in good condition with Handicapped person Ramp and fire extinguisher are provided .The Buildings in not constructed under the supervision of this office and R.C.C. Design is not Approved by This Office and Quality control tests are not carried by this office So This office canot certity the life of building .As well as structural stability of building .As per visual inspection the building seems to be in Good condition and good for use as a school building .

Countersigned

Executive Engineer
Public Works Division Aurangabad.

Assistant Engineer Grade I
Construction Sub Dn No 1
Aurangabad.